



Architectural Testing

Performance Test Report
Estolga® 1000 Wet Seal Panel System

ASTM Test Results		
<u>Test Method</u>	<u>Title of Test</u>	<u>Results</u>
ASTM E-283	Air Infiltration 1.60 psf (25 mph) 6.27 psf (50 mph)	<0.01 cfm/ft ² = Pass <0.01 cfm/ft ² = Pass
ASTM E-331	Water Resistance 15.05 psf	No Leakage
ASTM E-330	Uniform Load Deflection (span = 46") +120.0 psf (positive) -80.0 psf (negative)	0.51" = Pass 0.82" = Pass
ASTM E-330	Uniform Structural Load (span = 46") +180.0 psf (positive) -100.0 psf (negative)	0.02" = Pass 0.18" = Pass
* Refer to Report No. 96663.02-109-44 performed by Architectural Testing, Inc.		